

Existing Area Source Boiler with Coal Fuel Subcategory

Capacity or Use type	Oxygen Trim System?	Initial Notice of Applicability	Conduct an Initial Tune-up	Tune-up Frequency	Submit Notification of Compliance Status for Tune-ups	Complete One-Time Energy Assessment	Submit Notification of Compliance Status for Energy Assessment	Required to Meet Emission Limits	Submit Notification of Compliance Status for Emission Limits	Emission Performance Test Frequency
Any Capacity	Yes	01/20/14	03/21/14	Every five(5) years	Every March 1 st after a tune-up is completed	–	–	–	–	–
	No	01/20/14	03/21/14	Every two (2) years	Every March 1 st after a tune-up is completed	–	–	–	–	–
≥ 10 MMBTU/hr	Yes	01/20/14	03/21/14	Every two (2) years	Every March 1 st after a tune-up is completed	03/21/14	07/19/14	2.2 x 10 ⁻⁵ lb Hg/MMBTU, 420 ppm CO by volume on a dry basis	07/19/14 or within 60 days of completing performance stack test	None if initial performance test is less than or equal to half the limit, otherwise every three (3) years
≥ 10 MMBTU/hr	No	01/20/14	03/21/14	Every five (5) years	Every March 1 st after a tune-up is completed	03/21/14	07/19/14	2.2 x 10 ⁻⁵ lb Hg/MMBTU, 420 ppm CO by volume on a dry basis	07/19/14 or within 60 days of completing performance stack test	None if initial performance test is less than or equal to half the limit, otherwise every three (3) years